

Smart, Mark

From: Jeffrey Slark <jslark@nycoa.com>
Sent: Wednesday, November 13, 2019 1:28 PM
To: Larson, Stephanie; Hilton, Joy (Palmer)
Subject: NYCOA cooling water pH (permit NH00000116)
Attachments: ATT00001.txt

Hello,

Today there was an occurrence of our non-contact cooling water pH readings outside of the permit range. We believe the reason for the low effluent pH is due to the low pH coming in from the Merrimack River.

- 11/13/19
 - o Intake reading: 6.22 (duplicate 6.19)
 - o Effluent reading: 6.17 (duplicate 6.19)

Please let me know if you have any questions.

Thank you,

Jeff Slark

EHS & Security Coordinator



Nylon Corporation of America

333 Sundial Ave.

Manchester, NH 03103

Phone: 603-627-5150 (x318)

Email: jslark@nycoa.com